



OFFICE OF THE DY FIRE OFFICER,
KORAPUT CIRCLE, KORAPUT

No. 2918 / KPT Crl.

Dtd 29.11.2020

To

The Secretary,
Netaji English Medium School, Semiluguda,
Dist- Koraput.

Ref: - Your application in Form-III requesting for Fire Safety Certificate.

Sub: - Regarding issuance of Fire Safety certificate in respect of Netaji English
Medium School, Semiluguda, Dist- Koraput.

Sir,

With reference to the subject cited above this is to intimate that, as per Rule 3(j) of Odisha Fire Prevention and Fire safety (Amendment) Rules-2019, the following Educational Buildings are only required to obtain Fire safety certificate.

1. Having height of 12 mtr and above or.
2. Having a built up area of 1000 square meters or above, or
3. Having 03 storied buildings.

However, as shown in furnished plan, and undertaken verification by a team of Fire Service Officers on 28.11.2020, your educational institution contains total One Block having G+1 Floors. Height of the Block is 6.80 mtr approximately & total built up area is 769.50 square meters approximately

Hence, as per provisions of Rule 3(j) of Odisha Fire Prevention and Fire Safety (Amendment) Rules-2019, Fire Safety Certificate (F.S.C) is not required to the afore-said educational buildings as on date of verification i.e 28.11.2020. However 06 Nos of ABC (06kg) Fire Extinguisher. Hose Reel Hose @ 01 No in each floor connected to terrace tank with terrace pump of capacity 450 LPM has been installed.

Here with your application is disposed of accordingly.

Yours faithfully


29/11/20
Dy. Fire Officer,
Koraput Circle, Koraput
Koraput